

Index No. _____

Butler Rural Electric Cooperative Association, Inc. Schedule NMR-16

Replacing Schedule NRM-09

All Territory

Which was issued December 28, 2009

(Territory to which schedule is applicable)

The cooperative's bylaws, rules and regulations are supplemental to this schedule and are incorporated herein. Sheet 1 of 4

NET METERING RIDER

DEFINITIONS:

Customer-generator:

The owner or operator of a qualified electric energy generation unit which:

- (a) Is powered by a Renewable Energy Resource as defined by Kansas state statutes (see definition below);
- (b) Has an electrical generating capacity of not more than two hundred kilowatts;
- (c) Is located on a premises owned, operated, leased, or otherwise controlled by the Customer-generator;
- (d) Is interconnected and operates in parallel phase and synchronization with the Cooperative;
- (e) Is intended primarily to offset part or all of the Customer-generator's own electrical energy requirements;
- (f) Meets all applicable safety, performance, interconnection, and reliability standards established by the National Electrical Code, the National Electrical Safety Code, the Institute of Electrical and Electronics Engineers, Underwriters Laboratories, the Federal Energy Regulatory Commission, and any local governing authorities; and
- (g) Contains a mechanism that automatically disables the unit and interrupts the flow of electricity back onto the supplier's electricity lines in the event that service to the Customer-generator is interrupted.

Each meter connected under this Net Metering Rider defines a Customer-generator. A generator owned or operated by a Customer-generator cannot be connected in common with any other meter or be deemed to be for the purpose of serving the load connected to any other meter. To the extent that the Customer-generator controls the Renewable Energy Resources, and meets the requirements and accepts all of the obligations of this Net Metering Rider, the Customer-generator is not required to own the generating facilities.

Renewable Energy Resources:

Electrical energy produced from an energy resource or technologies defined as renewable in K.S.A. 17-4652, and amendments thereto, and also energy produced from municipal or other solid waste and animal waste.

Net metering:

A bi-directional metering process using equipment sufficient to measure the difference between the electrical energy supplied to a Customer-generator by a retail electric supplier and the electrical energy supplied by the Customer-generator to the retail electric supplier over an applicable billing period.

Peak load:

The one-hour maximum annual demand imposed by the Cooperatives retail load in the state.

| | | | | | |
|-----------|----------|-----|------|-------|----------------------|
| Issued | November | 23 | 2015 | By | |
| | Month | Day | Year | | Signature of Officer |
| Effective | January | 1 | 2016 | Title | |
| | Month | Day | Year | | President |

| | | |
|---|--------------------|-------------------|
| Butler Rural Electric Cooperative Association, Inc. | | Index No. _____ |
| | Schedule | NMR-16 |
| All Territory | Replacing Schedule | NRM-09 |
| (Territory to which schedule is applicable) | Which was issued | December 28, 2009 |

The cooperative's bylaws, rules and regulations are supplemental to this schedule and are incorporated herein.

Sheet 2 of 4

LIMITED AVAILABILITY:

Net metering service is available under this rider at points on the Cooperative's existing electric distribution system, located within its service area, for Customers operating Renewable Energy Resource. The net metering service is available to Customer-generators on a first-come, first-served basis until the total rated generating capability of all net metering interconnections during a calendar year equals or exceeds one percent of the Cooperative's peak load for the previous calendar year; or until the total rated generating capability of net metering interconnections equals five percent of the Cooperative's peak load during the previous year. Upon reaching either of these limits no further net metering service shall be available for that calendar year. This rider shall not be available for any electric service schedule allowing for resale. A Customer-generator shall have the alternative option of interconnecting renewable generation under the parallel generation provisions of the Cooperative's rules and regulations. However, renewable Customer-generators may not change between the net metering and parallel generation rider without the prior approval of the Cooperative and the Cooperative's power supplier, and such elections shall not be for periods less than one-year.

APPLICABILITY:

This net-metering rider is applicable to Customer-generators with a Cooperative-approved interconnection agreement. This schedule is not applicable where the nameplate capability of the Customer's electrical generating system exceeds 200 kW.

CHARACTER OF SERVICE:

Alternating current, 60 cycles, at the voltage and phase of the Cooperative's established secondary distribution system immediately adjacent to the service location.

BILLING AND PAYMENT:

The Cooperative shall render a bill for net consumption at approximately 30-day intervals during the Cooperative's normal billing interval. Net consumption is defined as the kWh supplied by the Cooperative to the Customer-generator minus kWh supplied by the Customer-generator and returned to the Cooperative's grid during the billing period. Any net consumption shall be valued as follows:

To the extent the net consumption is positive (i.e. Customer-generator took more kWh from the Cooperative during the billing period than Customer-generator produced), the eligible Customer-generator will be billed in accordance with the Cooperative's standard rate for Energy Charges (for the net consumption), and for any Customer Charges, Demand Charges, and/or any Minimum Charges that would otherwise be applicable to the Customer under the standard rate..

To the extent the net consumption is negative (i.e. Customer-generator produced more kWh during the billing period than the Cooperative supplied), the Customer-generator will pay applicable Customer Charges, Demand Charges, and/or any Minimum Charges that would otherwise be applicable to the Customer under the standard rate; and the excess electric energy shall be retained by the supplier as a contribution to fixed costs associated with owning and maintaining the facilities required to provide electric service when the Customer-generator cannot meet its own supply needs.

| | | | | | |
|-----------|----------|-----|------|-------|----------------------|
| Issued | November | 23 | 2015 | By | |
| | Month | Day | Year | | Signature of Officer |
| Effective | January | 1 | 2016 | Title | |
| | Month | Day | Year | | President |

| | | |
|---|--------------------|-------------------|
| Butler Rural Electric Cooperative Association, Inc. | | Index No. _____ |
| | Schedule | NMR-16 |
| | Replacing Schedule | NRM-09 |
| All Territory | Which was issued | December 28, 2009 |
| (Territory to which schedule is applicable) | | |

The cooperative's bylaws, rules and regulations are supplemental to this schedule and are incorporated herein. Sheet 4 of 4

to allow an attachment of a net metered facility or for the acts or omissions of a Customer-generator that cause loss or injury, including death, to any third party. The Customer-generator agrees to hold the Cooperative harmless from injury or property damage incurred by any person and arising out of the ownership, operation, maintenance, or use of the customers electrical generation facility and to indemnify the Cooperative against all liability and expense related thereto.

9. Prior to installing and interconnecting a Renewable Energy Resource the Customer shall enter into a standard interconnection contract with the Cooperative setting forth the conditions related to technical and safety aspects of parallel generation.
10. Service under this Net Metering Rider is subject to the Cooperative's Rules and Regulations as adopted by the Board of Trustees and any subsequently approved modifications that may be adopted by said Board during the term of service.
11. The Customer-generator shall, at its own expense, maintain in force general liability insurance without any exclusion for liabilities related to the interconnection. The amount of such insurance shall be sufficient to insure against all reasonably foreseeable direct liabilities given the size and nature of the generating equipment being interconnected, the interconnection itself and the characteristics of the system to which the interconnection is made. For Renewable Energy Resource systems having a maximum nameplate generating capability of 10 kW or less, a Customer-generator whose system meets the standards specified in (f) above shall not be required to install additional controls, perform or pay for additional tests or distribution equipment or purchase additional liability insurance other than such general liability insurance. For Renewable Energy Resource systems having a maximum nameplate generating capability of greater than 10 kW, the Board of Trustees shall: (1) Set forth safety, performance and reliability standards and insurance requirements; and (2) establish the qualifications for exemption from a requirement to install additional controls, perform or pay for additional tests or distribution equipment or purchase additional liability insurance.
12. Applications by a Customer-generator for interconnection of the qualified generation unit to the distribution system shall be accompanied by the plan for the Customer-generator's electrical generating system, including, but not limited to, a wiring diagram and specifications for the generating unit, and shall be reviewed and responded to by the Cooperative within 30 days after receipt for systems of 10 kilowatts or less and within 90 days after receipt for all other systems. Prior to the interconnection of the qualified generation unit to the supplier's system, the Customer-generator shall furnish the Cooperative a certification from a qualified professional electrician or engineer that the installation meets the requirements of paragraph f, above. If the application for interconnection is approved by the Cooperative and the Customer-generator does not complete the interconnection within one year after receipt of notice of the approval, the approval shall expire and the Customer-generator shall be responsible for filing a new application. Upon the change in ownership of a qualified Renewable Energy Resource, the new Customer-generator shall be responsible for filing a new application under this section.
13. Ownership of all renewable energy credits, greenhouse gas emission credits and any other renewable energy attributes related to any electricity produced by the eligible renewable energy resource shall be retained by the Customer-generator.

| | | | | | |
|-----------|----------|-----|------|-------|----------------------|
| Issued | November | 23 | 2015 | | |
| | Month | Day | Year | By | Signature of Officer |
| Effective | January | 1 | 2016 | Title | President |
| | Month | Day | Year | | |